

FEVA Form 32-633

MONTHLY UNDERGROUND STORAGE TANK (UST) INSPECTION RECORD

Activity: _____ **Building #:** _____ **Tank #:** _____

UST Inspector's Name: _____ **Year:** _____

	Date	Date	Date	Date	Date	Date
Automatic Tank Gauging System: Inspect for proper operation.						
Spill Buckets: Ensure spill buckets are clean and empty.						
Overfill Alarm: Inspect for proper operation. Can a delivery person hear or see the alarm when it alarms?						
Ground Surface around Fill Port: Check for signs of leakage.						
Fill and Monitoring Ports: Inspect all fill/monitoring ports and other access points to make sure that the covers and caps are tightly sealed and locked.						
Spill and Overfill Response Supplies: Inventory and inspect the emergency spill response supplies. If the supplies are low, restock the supplies. Inspect supplies for deterioration and damage.						
Dispenser Hoses, Nozzles, and Breakaways: Inspect for loose fittings, deterioration, obvious signs of leakage, and damage.						
Dispenser and Dispenser Sumps: Open each dispenser and inspect all visible piping, fittings, and couplings for any signs of leakage. If any water or fuel is present, remove it and dispose of it properly. Remove any debris from the sump.						
Piping Sumps: Inspect all visible piping, fittings, and couplings for any signs of leakage. If any water or product is present, remove it and dispose of it properly. Remove any debris from the sump.						
Tank Gauges: Inspected and ensure they are proper operation.						

Initial each box below the date of the inspection which will indicate that the device/system was inspected and OK on that date.